

IMPORTANT SAFETY INFORMATION. READ AND FOLLOW ALL SAFETY INSTRUCTIONS. Follow label information and instructions concerning Wet or Damp Locations, installation near combustible materials, insulation, building materials, and proper lamping. Do not install in areas subject to combustible vapors or gases. Before wiring to power supply and during servicing or relamping, turn off power at fuse or circuit breaker. **All servicing or relamping must be performed by qualified service personnel. Product must be grounded to avoid potential electric shock or other potential hazard. Product must be mounted in locations and at heights and in a manner consistent with its intended use, and in compliance with the National Electrical Code and local codes.** The use of accessory equipment not recommended by the manufacturer or installed contrary to instructions may cause an unsafe condition. Do not block light emanating from product in whole or part, as this may cause an unsafe condition. Do not allow items such as drapes, curtains, screens or the like to come into contact with the product or to block light from the product, as this may cause an unsafe condition. **WARNING** - This product contains chemicals known to the State of California to cause cancer, birth defects and/or other reproductive harm. Thoroughly wash hands after installing, handling, cleaning, or otherwise touching this product.

INSTALLATION INSTRUCTIONS CFSCB 813/18/26

1. Remove cover plate by loosening the (2) cover plate screws and sliding the cover plate until screw heads clear the keyholes.
2. Thread supply wire (line, common and ground) from outlet box installed in ceiling through center hole of drum housing. Place drum housing over outlet box. Twist drum housing clockwise to engage outlet box screw heads. Secure drum housing to ceiling.
3. Make wire connections in top of drum housing between supply wires and ballast/socket tray assembly. (green to green, white to white and black to black).
4. Install (2) compact fluorescent lamps per relamp label (order separately).
5. Install trim (order separately).

